

Strojírenský zkušební ústav, s.p. (Engineering Test Institute, Public Enterprise)

Hudcova 424/56b, 621 00 Brno, Czech Republic

CORRECTED COPY

Page 1 of 54

TEST REPORT 31-8951/T2

Product:

Hot-water boilers burning wood pellets

with automatic fuel supply

Type designation:

PelTec – lambda 12

PelTec - lambda 48

Customer:

Centrometal d.o.o.

Glavna 12 40306 Macinec

Croatia

Manufacturer:

Centrometal d.o.o.

Glavna 12 40306 Macinec

Croatia

Employee responsible for review and evaluation:

Ing. Stanislav Buchta

Report issue date:

2013-03-29

Distribution list:

1 copy to the Engineering Test Institute

1 copy to the Customer

^(**) Thus indicated parts of the Report contain findings, the verification method of which are not the tests within the meaning of ČSN EN ISO/IEC 17025.

The tests were performed based on Order B-44560 of 2012-09-10, Contract B-45560/31 of 2012-09-17 and the Amendment to the Contract of 2013-03-27.

Based on the technical assessment of all the product versions

PelTec - lambda 12, PelTec - lambda 18, PelTec - lambda 24, PelTec - lambda 36, PelTec - lambda 48,

the following - the most complex products have been selected as the representatives to be tested, i.e. the types

PelTec - lambda 12, PelTec - lambda 48.

The identical constructional design of the critical parts of all the products has been assessed. In particular, the following characteristics of the products have been assessed:

- Materials used
- Constructional design
- Safety, control and regulation elements
- Regulation method
- Circuitry design
- Dimensions, design, surface treatment
- Identical technological processes in manufacturing

With regard to the findings specified above it may be stated that the versions have no different characteristics regarding the nature of the hazard they present; therefore, the results of the tests performed on the selected representatives may be used to evaluate respective requirements indicated in Chapter IV, for all versions of the products.

I. Product description, intended use and mode of application

The hot-water boilers burning wood pellets with automatic fuel supply, PelTec - lambda 12, PelTec - lambda 18, PelTec - lambda 24, PelTec - lambda 36, and PelTec - lambda 48, are intended for heating of residential houses and similar buildings. The boilers have been designed for burning of wood pellets.

The boiler assembly comprises the main boiler body and burner, and screw conveyor and fuel storage container (see enclosed technical documentation). The boiler body is a weldment of steel sheets. At the top part of the boiler is the panel with control, regulation and safety elements. The boiler body is thermally insulated with mineral felt.

The detailed descriptions of individual component sets are included in the enclosed technical documentation to Task 31-8951.

II. Sample tested

The capacity versions that have been the subject of the proceedings:

Boiler capacity version	EKV No.	Place of testing
PelTec - lambda 12	001	Centrometal d.o.o.
PelTec - lambda 48	003	Centrometal d.o.o.

The visual inspection, tests and evaluations were conducted by Ing. Michal Havlů, an SZU test engineer, at the test station of Centrometal d.o.o., Glavna 12, 40306 Macinec, Croatia, in October 2012.

The tests were performed by means of measuring and test equipment with valid calibration.

III. Measuring and test equipment

No.	Description	Inventory number	Calibration valid until	Accuracy
1.	Combustion product analyser, Horiba, type 680 P	92-0004	Calibration prior to each measurement	see CRM 103000237769 see CRM 103000237770
2.	Weighing machine	02-2290	10/2015	see Calibration Sheet 6051-KL-H-0651-10
3.	Water meter, NW 20	02-1575	03/2015	see Calibration Sheet AKL-P/006/2009
4.	Measuring centre	02-2241	12/2013	see Calibration Sheet 110002
5.	Moisture meter, thermometer	11-6258	11/2015	see Calibration Sheet 7630F/09
6.	Barometer	11-2541	11/2013	see Calibration Sheet 613-KL-K011-08
7.	Draught gauge	11-7275	01/2015	see Calibration Sheet 0144F/11
8.	Stop watch	99-0760	10/2015	see Calibration Sheet 2850E-07
9.	Calorimeter, IKA, type C 5000	02-2236	03/2015	± 0.12 MJ/kg
10.	Elemental analyser, Perkin Elmer, type 2400 CHNS	02-2107	03/2015	± 0.2 % rel.
11.	Gravimat, SHC 501	02-2328	12/2013	see Calibration Sheets 090177 (8,9), 090180
12.	Laboratory scale	02-1458	06/2015	see Calibration Sheet 6051-KL-H376-09
13.	Weighing machine, Ohaus, MB 45	02-2274	06/2015	see Calibration Sheet 6051-KL-H374-09
14.	Manometer	11-1985	02/2014	see Calibration Sheet 090162
15.	Prandtl tube, 0.3 m	ME 484	11/2015	see Calibration Sheet 5012-KL-RS090-09
16.	Psychro-meter, H 4220	92-0005	12/2013	see Calibration Sheet 090176



IV. Results of tests and evaluation

	Name and specifica-	Technical standard,	Source materials	Evaluation	
No.	tion	regulation applied		Test	Evalua- tion
1.**	General requirements	EN 303-5:2012 Art. 4.1	Pages 6 – 7		+
2.**	Construction requirements	EN 303-5:2012 Art. 4.2, 4.2.1, 4.2.1.1, 4.2.1.2, 4.2.2, 4.2.2.1, 4.2.2.2, 4.2.2.3, 4.2.2.4, 4.2.4, 4.2.4.1, 4.2.4.2, 4.2.4.3, 4.2.4.4, 4.2.4.5, 4.2.4.6, 4.2.4.7, 4.2.4.8, 4.2.4.9, 4.2.4.10, 4.2.4.11, 4.2.4.12	Pages 8 – 12		+
3.**	Safety requirements	EN 303-5:2012 Art. 4.3, 4.3.1, 4.3.3, 4.3.3.1, 4.3.3.2, 4.3.3.3, 4.3.3.4, 4.3.3.5, 4.3.4, 4.3.5, 4.3.6, 4.3.7, 4.3.8, 4.3.8.1, 4.3.8.2, 4.3.8.3, 4.3.8.4, 4.3.9, 4.3.9.1, 4.3.9.2, 4.3.9.3	Pages 13 – 22		+
4.**	Performance requirements	EN 303-5:2012 Art. 4.4, 4.4.1, 4.4.2, 4.4.3, 4.4.4, 4.4.5, 4.4.6, 4.4.7	Pages 23 - 24		+
5.**	Marking	EN 303-5:2012 Art. 7, 7.1, 7.2, 7.3	Page 25		+
6.**	Technical documentation, supplied with boiler	EN 303-5:2012 Art. 8, 8.1, 8.2, 8.3, 5.16.1	Pages 26 - 29		+
7.	Strength and tightness of pressurized components (1001.1*)	EN 303-5:2012 Art. 5.4, 5.4.1, 5.4.2	Page 30	+	
8.	Surface temperature test (1003*)	EN 303-5:2012 Art. 5.12, 5.16.4, 4.3.6	Pages 31 - 33	+	
9.	Test of heat output, input and efficiency (1004.1*) Test of combustion prod- uct temperature (1004.2*)	EN 303-5:2012 Art. 4.4.2, 4.4.3, 5.7, 5.8, 5.10 EN 303-5:2012 Art. 4.4.3	Pages 34 - 38	+	
10.	Combustion efficiency - emissions (1005.1*)	EN 303-5:2012 Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4	Pages 39 - 40	+	
		EN 303-5:2012 Annex C, Deviation from Austria, C.2.2, C.2.3	Pages 41 – 42 Page 54	+	
	Test of heat output, input	EN 303-5:2012 Annex C, C.3 Deviation from Croatia	-	0	
11.	and efficiency (1004.1*)	EN 303-5:2012 Annex C, Deviation from Denmark, C.4.1, C.4.2	Pages 43 - 44	+	
	Combustion efficiency - emissions (1005.1*)	EN 303-5:2012 Annex C, Deviation from Germany, C.5.1, C.5.2	Pages 45 - 46	+	
	(1005.1)	EN 303-5:2012 Annex C C.6 Deviation from Switzerland	Pages 47 - 48	+	



	Name and specifica-	Technical standard.	Source	Evaluation	
No.	tion	regulation applied	materials	Test	Evalua- tion
11.	Test of heat output, input and efficiency (1004.1*) Combustion efficiency test - emissions (1005.1*)	EN 303-5:2012 Annex C C.8 Deviation from Italy	Page 49	PelTec - lambda 12 0 PelTec - lambda 48 +	
12.	Function test of control, regulation and safety elements (1006.1*) Combustion efficiency test - emissions (1005.1*)	EN 303-5:2012 Art. 5.13, 5.14, 5.16.2, 5.16.3 EN 303-5:2012 Art. 5.9, 5.10.4	Pages 50 - 52	+	

Note:

No.:

(**) Not a test

Evaluation:

+ Requirement fulfilled

- Requirement not fulfilled

x Not assessed

Requirement assessed:

General requirements

Requirement specification:

EN 303-5:2012 Art. 4.1


Sample assessed:

PelTec - lambda 12, PelTec - lambda 48

Evaluation results:

see the following Table

Requirement	Requirement specification	Evaluation	Note
General requirements	EN 303-5:2012 Art. 4.1		
Boilers shall be fire-resistant and safe to operate. They shall be made of non-combustible materials according to EN 13501-1 and shall be resistant to deformation. They shall be made such that:	7 N.C. 71. I	+	
a) they can withstand stresses arising during normal opera-		+	
tion, the heat carrier (water) does not become heated to a dangerous extent (≤ 110 °C);		+	
 gases do not leak from the boiler or the stoking device or from an integrated hopper in dangerous quantities into the place of installation or into the fuel line, 		+	
NOTE: Safety requirements regarding harmful gas concentrations of course need to be considered. Both these elements, however, strongly depend on the place of installation and the fuel storage discharge system and therefore fall outside of the scope of this standard. This requirement is deemed to be fulfilled if the requirements of the leakage of the boiler and of the emissions are met and there is no visible smoke emerging from the boiler into the test room at normal operation during type test. a) flames do not flare out and embers do not fall out when the boiler is operated correctly;	EN 303-5:2012 Art. 4.1	+	
 b) dangerous accumulation of combustible gases (> 5 % CO) in the combustion chamber and in the flues is prevented. 		+	
For the evaluation of the hazardous situation, the CO-concentration in the flue gas measuring section should not exceed the critical values for a time period greater than 1 min. Combustible materials shall be allowed for the following: c) internal components of controls and safety equipment;		+	
d) operating handles;		+	
e) electrical equipment;		+	
f) components of accessories (e.g. burner cover);		T	
g) additional or supplemental optical outer covers (e.g. an additional decorative cover).		+	
Component parts of covers, operating controls, safety devices and electrical accessories shall fulfil the requirements of resistance against heat and fire in either EN 60335-1 or EN 60730-1.		+	





Requirement	Requirement specification	Evaluation	Note
Component parts of covers, operating controls, safety devices and electrical accessories shall be arranged in such a way that their surface temperatures, under steady state conditions, do not exceed those specified either by the manufacturer or in the component part standard.		+	
The materials for the parts subject to pressure shall be in accordance with generally accepted technical requirements. They shall be suitable for the purpose and intended use. Documented proof of mechanical and physical properties of materials used and their chemical composition shall be obtained from the supplier.	EN 303-5:2012	+	
The design of the boiler shall be such that it can be handled safely. It shall be designed and packaged so that it can be stored safely and without damage.	Art. 4.1	+	
Where the weight, size or shape of the boiler or its components prevents them from being moved by hand, they shall be fitted with means to lift them easily.		+	
Constructional parts accessible during use and maintenance shall be free from sharp edges and corners that might cause damage or personal injury during use or maintenance.		+	
Motors and fans shall be mounted in such a way as to minimize noise and vibration.		+	

Note:

- Compliant Non-compliant Not applicable
- 0
- Not assessed

Evaluation drafted by: Ing. Michal Havlů

Person responsible for the evaluation:

Ing. Stanislav Buchta

Date:

10/2012

Signed:

Date:

10/2012

Signed:



Requirement assessed: **Construction requirements**

EN 303-5:2012

Art. 4.2, 4.2.1, 4.2.1.1, 4.2.1.2, 4.2.2, 4.2.2.1, 4.2.2.2, 4.2.2.3, Requirement specification:

4.2.2.4, 4.2.4, 4.2.4.1, 4.2.4.2, 4.2.4.3, 4.2.4.4, 4.2.4.5,

4.2.4.6, 4.2.4.7, 4.2.4.8, 4.2.4.9, 4.2.4.10, 4.2.4.11, 4.2.4.12

Sample assessed: PelTec - lambda 12, PelTec - lambda 48

Evaluation results: see the following Table

Requirement	Requirement specification	Evaluation	Note
Construction requirements	EN 303-5:2012		
Construction requirements	Art. 4.2		
Production documentation	EN 303-5:2012 Art. 4.2.1		
Drawings The drawings and/or the relevant documentation shall include at least the following information: a) the specification of the material; b) the welding process, the seam type (generally the symbol for the seam type is sufficient) and the welding fillers; c) the maximum allowable operating temperature, in °C; d) the maximum allowable operating pressure, in bar; e) the type test pressure, in bar. f) the nominal heat output or the heat output range for every boiler size, in kW, in accordance with the fuel(s) recommended for use in the boiler.	EN 303-5:2012 Art. 4.2.1.1	+ + + +	
 Manufacturing controls A Quality Manual shall be compiled on the inspections and tests necessary during the manufacturing process. The Manual shall: 1) describe the inspection system; 2) specify the person responsible for quality assurance; 3) specify the necessary inspections and tests as well as the pertinent limit values and; 4) lay down the requisite measuring and testing equipment and their inspection. 	EN 303-5:2012 Art. 4.2.1.2	+ + + + +	
Heating boilers made of steel and non-ferrous materials	EN 303-5:2012 Art. 4.2.2		
Execution of welding work Boiler manufacturers who carry out welding work shall meet the requirements of EN 287-1 and EN ISO 9606-2 as follows: - only welders who are qualified in the welding of the materials to be processed shall be used; - equipment shall be available to allow defect-free welding to be carried out; - supervision of the welding shall be carried out by staff qualified in welding (at least one supervisor shall be qualified).	EN 303-5:2012 Art. 4.2.2.1	+ + +	Enclosed technical documenta- tion.

Report 31-8951/T2 Page 9 of 54



Requirement	Requirement specification	Evaluation	Note
Welding seams and welding fillers The materials shall be suitable for welding. NOTE 1 The materials in Table 1 are suitable for welding and do not require additional heat treatment after welding.		+	
The welded seams shall not show any cracks or lack of fusion and shall be defect free over the whole cross section for butt welds. One-sided fillet welds, and half Y-welds which have been welded through, shall be kept substantially free from bending stresses. Smoke tubes, inserted stays and similar components need not be counter welded.		+	
Double fillet welds are only permissible when sufficiently cooled. Projections into the flue gas side in areas of high thermal stresses shall be avoided.		+	Enclosed technical documenta- tion (welding
Corner welds, edge welds and similar welded connections, which shall only be subject to high bending stresses during production and operation, are to be avoided.	EN 303-5:2012 Art. 4.2.2.2	+	procedures).
When welding longitudinal stay bars or stay tubes, the shearing cross section of the fillet weld shall be 1.2 times the required stay bar or stay tube cross sectional area.		+	
The permissible types of weld and appropriate material thicknesses are given in Table 2 and these parameters shall be met.		+	
Welding fillers shall be suitable for the material being used.		+	
NOTE 2: The terms given in Table 2 are in accordance with EN 22553; the reference numbers of welding processes are in accordance with ISO 857-1, ISO 857-2 and EN ISO 4063.		+	
Parts of steel subject to pressure		+	
The steels listed in Table 1 shall be used. Materials and wall thicknesses other than those specified shall only be used on the production of appropriate evidence, with regard to (at least) their equivalent corrosion resistance, heat resistance and strength to non-alloy steel at the material thicknesses specified in Table 1 for the particular application/usage.	EN 303-5:2012 Art. 4.2.2.3	+	Enclosed technical documenta- tion (welding procedures).
The specification of the materials shall be documented by a works certificate in accordance with EN 10204. These certificates shall be obtained by the boiler manufacturer. This does not apply to components, e.g. sockets up to DN 50, screws and nuts.		+	

Report 31-8951/T2 Page 10 of 54



Requirement	Requirement specification	Evaluation	Note
Minimum wall thicknesses			
The minimum wall thicknesses listed in Table 3 have been specified in order to take into account the following:		+	
 a) the maximum allowable operating pressure; 		+	
b) the nominal heat output;		+	
c) the material properties.		+	
For boilers which consist of a combination of individual geometrically identical parts (sections), the requirements of the minimum wall thickness for the complete range of the nominal heat output of the boiler shall be in accordance with the individual boiler sections as specified in Table 3. The wall thickness tolerance for carbon steels shall be as	EN 303-5:2012 Art. 4.2.2.4	+	
specified in EN 10029.		+	
The minimum wall thicknesses according to Table 3 apply to pressure-loaded sheets, tubes (except immersion coils and safety heat-exchangers) and forgings. Smaller wall thicknesses shall be permitted upon the production of evidence demonstrating equivalence with regard to corrosion, heat resistance and strength.		+	Enclosed technical documenta- tion (semi- finished products).
Design requirements	EN 303-5:2012 Art. 4.2.4		
Venting of the water sections The boiler and its components shall be designed in such a way that their respective water sections can be fully vented. The boiler shall be designed in a way that under normal operation in accordance with the manufacturer's instructions no undue boiling occurs. NOTE: Boiling can be detected by boiling noise.	EN 303-5:2012 Art. 4.2.4.1	+	
Cleaning of heating surfaces			
The heating surfaces shall be accessible from the flue gas side for inspection and cleaning with chemical agents and brushes. A sufficient number and appropriate arrangement of cleaning openings shall be provided. If special tools (for example special brushes) are required for cleaning and maintenance of the boiler, these shall be supplied.	EN 303-5:2012 Art. 4.2.4.2	+	
Inspection of the flame A facility shall be provided which allows inspection of the flame or fire bed. If this facility is a door, then hazard-free inspection shall be possible. NOTE The facility of an inspection window is recommended.	EN 303-5:2012 Art. 4.2.4.3	+	
Water tightness Holes for screws and similar components which are used for the attachment of removable parts shall not enter into spaces through which water flows. This does not apply to pockets for measuring or control and safety equipment	EN 303-5:2012 Art. 4.2.4.4	+	

Report 31-8951/T2 Page 11 of 54



Requirement	Requirement specification	Evaluation	Note
Replacement parts Replacement and spare parts (e.g. inserts, shaped fire-bricks, turbulators etc.) shall be designed, made or marked in such a way that their installation shall be correct in accordance with the manufacturer's instructions.	EN 303-5:2012 Art. 4.2.4.5	+	
Boiler shell tappings Boiler shell tappings shall comply with EN 10226-1, ISO 7-2, EN ISO 228-1, EN ISO 228-2; flange connections shall comply with ISO 7005-1, ISO 7005-2 and ISO 7005-3. The arrangement of the tappings shall be such that they are easily accessible and the function of each respective connection can be adequately fulfilled. There shall be sufficient space around the connection to allow the installation of the connecting pipes (flanges, bolts) with the necessary tools.			
Threaded pipe connections above 2 inches (DN 50) are not recommended. Threaded pipe connections with nominal diameters above 3 inches (DN 80) shall not be permitted. This information shall be supplied with the boiler. If connections are fitted with flanges, the mating flanges and seals shall also be supplied except where standardised flanges and seals are available.	EN 303-5:2012 Art. 4.2.4.6	+	
The minimum size for flow outlet shall be DN 20 . The boiler shall have at least one connection for filling and emptying. This connection may be common. The size of the connection shall be as a minimum: — G 1/2 for nominal heat outputs up to 70 kW; — G 3/4 for nominal heat outputs above 70 kW. It is possible to provide these connections outside the boiler if satisfactory filling and emptying of the boiler can be assured.			
Every boiler shall be equipped with at least one immersion pocket which is used for temperature control, a safety temperature limiter and a thermometer. If a threaded pipe connection is required, the minimum nominal diameter shall be G 1/2. Alternative arrangements are allowed, provided that the control devices are supplied with the boiler, and that they cannot be substituted by other components. The immersion pockets shall be designed so that an unintended change of position of the temperature sensor is avoided. The position of the immersion pocket shall be chosen in such a way that the highest temperature of the boiler water is recorded with sufficient accuracy. Where additional connections for safety devices such as a pressure detector, manometer, low water cut-out device or a safety valve are provided, then their size (especially the size of the safety valve), shall be determined according to the output of the boiler. NOTE For further information on safety valves, see EN 12828.	EN 303-5:2012 Art. 4.2.4.7	+	

Report 31-8951/T2 Page 12 of 54



Requirement	Requirement specification	Evaluation	Note
Thermal insulation All boilers shall be fitted with thermal insulation. The thermal insulation shall withstand normal thermal and mechanical stresses. It shall be made of non-combustible material and shall not give off fumes during normal running.	EN 303-5:2012 Art. 4.2.4.8	+	
Water side resistance of the boiler The water side resistances are to be determined for those flows which correspond to the nominal heat output with two temperature differences of 10 K and 20 K between the flow and return connections of the boiler. The results are to be stated in mbar for each boiler size and shall correspond to the values indicated by the manufacturer.	EN 303-5:2012 Art. 4.2.4.9	+	
Integral fuel hopper A boiler with integral fuel hopper shall be made of fire resistant material according to EN 13501-2. The volume shall be limited to a maximum of 1.5 m³. The hopper shall be designed in such a way that the fuel moves freely until the hopper is empty.	EN 303-5:2012 Art. 4.2.4.10	+	
Fuel chamber The fuel chamber shall be designed in such a way that the fuel moves freely and the duration of the combustion period is assured.	EN 303-5:2012 Art. 4.2.4.11	+	
Ash chamber The capacity of the ash chamber shall be adequate for a combustion period of at least 12 h using the stipulated fuel at nominal heat output. It shall be designed to ensure the unobstructed flow of combustion air under the grate. If the system is designed with devices for automatic ash and clinker removal, the above requirement shall be considered as having been met.	EN 303-5:2012 Art. 4.2.4.12	+	

Note:

- + Compliant
- Non-compliant
- 0 Not applicable
- x Not assessed

Evaluation drafted by: Ing. Michal Havlů Date: 10/2012 Signed:

Person responsible for the evaluation:

Ing. Stanislav Buchta Date: 10/2012 Signed:

v. 3.00



Requirement assessed: Safety requirements

EN 303-5:2012

Art. 4.3, 4.3.1, 4.3.3, 4.3.3.1, 4.3.3.2, 4.3.3.3, 4.3.3.4, 4.3.3.5, 4.3.4, 4.3.5, 4.3.6, 4.3.7, 4.3.8, 4.3.8.1, 4.3.8.2, 4.3.8.3, 4.3.8.4, Requirement specification:

4.3.9, 4.3.9.1, 4.3.9.2, 4.3.9.3

Sample assessed: PelTec - lambda 12, PelTec - lambda 48

Evaluation results: see the following Table

Requirement	Requirement specification	Evaluation	Note
Potential hazards caused by the boiler, including the operation of the firing system and any stoking device, shall be avoided by either constructional means or by, the use of safety devices. Safety shall be maintained in the event of possible failures in the safety device itself. The manufacturer shall undertake a risk assessment covering all potential hazards of the boiler and the measures how to avoid or control them in a safety concept. Control functions within the safety concept shall be classified and realized accordingly. The risk assessment shall be performed according to EN ISO 12100 with particular emphasis on the type of the boiler and the fuel fired. Control functions are classified as follows. Class A: Control functions which are not intended to be relied upon for the safety of the application. Class B: Control functions which are intended to prevent an unsafe state of the appliance. Failure of the control function will not lead directly to a hazardous situation. For devices used in a class B control function, a single fault assessment of the device including use of software class B according to EN 60730-1 is required. Class C: Control functions which are intended to prevent special hazards such as explosion or whose failure could directly cause a hazard in the appliance. For devices used in a class C control function, a second fault assessment of the device including use of software class C according to EN 60730-1 is required. In case of safety routines realised in a programmable logic control the software shall meet the requirements of the appropriate software class B or C (including fault assessment shall cover at least the following: — elements given in 4.3.4 to 4.3.9; — boiler functions, including start-up, purge, ignition, flame supervision, flue gas flow, control of heat demand and combustion control. In the risk assessment, one of the above mentioned classifications of the control function shall be allocated to any identified hazard. The actuation of any control function class B or cl	EN 303-5:2012 Art. 4.3.1	+	Class B 31-8951/E 31-8951/ EMC

Report 31-8951/T2 Page 14 of 54



Requirement	Requirement specification	Evaluation	Note
Safety against back burning for automatic stoked boilers	EN 303-5:2012 Art. 4.3.3	+	
General Automatic stoking systems shall be designed to prevent back burning. The hazard of back burning is classified as a risk corresponding to safety level C in accordance with 4.3.1 and is related to the driving forces thermal conductance, backflow of ignitable gases and fire propagation backwards (see 4.3.3.2, 4.3.3.3 and 4.3.3.4). Back burning shall be avoided by constructional means and the implementation of one or more back burn safety devices. NOTE: The handling of the risk for back burning at safety level C includes the specification that sufficient safety measures need to be available. Adequate constructional means or safety devices shall: a) work always in the closed circuit current principle; b) avoid a back burning in the state of loss of power supply; c) avoid a back burning in the state of failure of stoking device or interruption of stoking device. In order to ensure that safety against back burning is adequately addressed, a risk assessment shall be undertaken. This assessment shall document the means employed to avoid the three driving forces for back burning and how they match the tested boiler. The documentation of the means employed shall include the specification of any chosen safety device. At least one of the safety systems shall continue to provide protection in the event of interruption of the fuel feed (e.g. blockage of the feed screw). The following mechanisms shall be avoided:	EN 303-5:2012 Art. 4.3.3.1	+ + +	
 d) Thermal conductance (4.3.3.2); e) Back flow of ignitable combustion gases (4.3.3.3); f) Fire propagation into fuel line (4.3.3.4). 		+ + +	

Report 31-8951/T2 Page 15 of 54



Requirement	Requirement specification	Evaluation	Note
Thermal conductance The surface temperature of the stoking device of the boiler (without insulation) or integrated hopper shall not exceed 85 °C in any operating state or in case of a failure. If this criterion is fulfilled by constructional means, no additional safety device is necessary. Thermal conductance shall be verified during the tests specified in 5.7 (thermal performance for nominal load and partial load), 5.13 to 5.16 and after the stopping of the stoking device of the boiler, with a permanent temperature measurement until a maximum is reached. For further information on verification of this requirement, see 5.16.4. Accepted solutions to prevent overheating in the stoking device due to thermal conductance are	Specification	+	
 an extinguishing device e.g. water sprinkler system and a safety temperature limiter adjusted to a maximum of 95 °C; 		0	
 an emergency discharge device emptying the stoking device without overfilling the boiler; which is reacting below 95 °C (alternatively 20 K increase to standard operation conditions); 	EN 303-5:2012 Art. 4.3.3.2	0	
 a stoking device which is cooled by a water circuit and the temperature of the water is limited by a cut out (e.g. water circuit is part of boiler circuit). Accepted solutions to prevent overheating in the integrated hopper due to thermal conductance in combination with accepted solutions for stoking devices are: 		0	
 an extinguishing device directly in the hopper e.g. water sprinkler system and an STB adjusted to a maximum of 95 °C; 		0	
 sufficient insulation of the hopper from hot parts of the boiler; 		+	
 naturally ventilated space between hopper and boiler body (separate casing). Criteria to verify the design of accepted solutions are listed in Table B.1. No test needs to be performed according to 5.16.4 if the chosen design is an accepted solution and the risk assessment proves the suitability for the boiler burner unit and the control algorithm interaction. If the risk assessment fails, further tests shall be required. 		+	

Report 31-8951/T2 Page 16 of 54



Requirement	Requirement specification	Evaluation	Note
Back flow of ignitable combustion gases into the fuel line or integral hoppers No significant flow of combustion gases in an ignitable concentration or carrying a critical amount of energy to ignite wood (e.g. sparks or hot gases) shall pass the constructional means or safety device(s) into the fuel line or into the hopper. Due to other safety reasons (for example to hinder poisoning by CO), any back flow of combustion gases shall be avoided (see 4.1).			
NOTE 1: Indications for significant back flow might include:			
 a) a temperature rise of more than 20 K compared to operation without back flow; b) CO concentration of more than 1 vol. % CO (dry) in the fuel line caused by any operational status or failure; c) accumulation of smoke in an integrated hopper This requirement applies during the tests according to 5.7 (thermal performance for nominal load and partial load including ignition, start up, continuous operation and shut down) and 5.13 to 5.16. 			
Accepted solutions to prevent back flow in the fuel line are listed as follows: - Safety device to maintain a continuous seal between the stoking device and the fuel line, e.g. cell feeder; - Safety device to seal the fuel line not during fuel		0	
supply but during all other phases of operation (e.g. lid) in combination with a boiler operating with a negative pressure (tightness requirements in closed state identical to continuously sealing safety devices);	EN 303-5:2012 Art. 4.3.3.3	+	
- Tight fuel hopper lid in combination with pressure equalization that works during normal operation and in case of start-up, shut down or power loss. Diffusion of hot gasses into the hopper shall be avoided by a connection for pressure equalization between the combustion air supply and the fuel hopper. The dimension of the connection shall only be sufficient to equalize pressure, not to accelerate fire propagation. Hopper lid shall be fitted with an interlock switch (according to H27 of EN 60730-2-5) which stops combustion air supply in case of an open lid;		0	
- Tight fuel hopper lid in combination with negative pressure operation of the boiler. Diffusion of hot gasses into the hopper shall be avoided by natural draught (e.g. inclined auger). The hopper lid shall be fitted with an interlock switch (according to H27 of EN 60730-2-5) which stops combustion air supply in case of an open lid;		0	
- Use of directed flow to create stable pressure conditions, e.g. injector, safety device to control fan rotation of supply fan or relevant pressure, which closes the fuel supply in case of failure		+	

Report 31-8951/T2 Page 17 of 54



Requirement	Requirement specification	Evaluation	Note
NOTE 2 Other solutions include the use of a flue gas fan to assure negative pressure condition in the boiler compared to pressure in the fuel line or hopper. The flue gas fan operation is controlled by a safety device for rotation or for pressure in combination with an additional safety device that prevents back flow in case fan failure or power loss. Criteria to verify the design of accepted solutions are listed in Table B.1.	EN 303-5:2012 Art. 4.3.3.3	0	
No test needs to be performed according to 5.16.4 if the chosen design is an accepted solution and the risk assessment proves the suitability for the boiler burner unit and the control algorithm interaction. If the risk assessment fails, further tests shall be required.			
Fire propagation into the fuel line or integral hopper Fire propagation into the fuel line or integral hopper shall be avoided in any operational state or in case of any failure. This does not include the thermal reaction of a small amount of fuel at the end of the stoking device, if there is no further reaction into the fuel line.			
NOTE: Indication for significant fire propagation might include: a) a temperature raise of more than 20 K in the stoking device above normal operation; b) a temperature of more than 85 °C on the surface of the			
stoking device; c) an accumulation of smoke in an integral hopper. This requirement shall be proven during the tests according to 5.7 (thermal performance for nominal load and partial load) and 5.13 to 5.16 with a permanent temperature measurement until the maximum temperature is reached.			
Accepted solutions to hinder fire propagation to the fuel line are listed as follows: - An extinguishing device, e.g. water sprinkler system and an STB adjusted to a maximum of 95 °C.		0	
 A safety device to seal continuously the supply line and with a sufficient fuel free distance and fuel free cross section, (e.g. cell feeder, rotary air lock) in combination with a design to prevent overfilling. A safety device to seal the fuel line not during fuel supply but during all other phases of operation (e.g. 		0	
lid) in combination with a boiler operating with a negative pressure (tightness requirements in closed state identical to continuously sealing safety devices), in combination with a design to prevent overfilling and with a sufficient fuel free distance and fuel free cross section.	EN 303-5:2012 Art. 4.3.3.4	+	
 An emergency discharge device emptying the stoking device without overfilling the boiler, which is reacting at a temperature limit not exceeding 95 °C (alternatively 20 K increase to standard operation conditions). 		0	

Report 31-8951/T2 Page 18 of 54



Requirement	Requirement specification	Evaluation	Note
 Inclined auger in combination with fuel transport slide to/in the combustion chamber and a safety limiter reacting at a temperature not exceeding 95 °C. 		0	
Criteria for accepted solutions to verify the design are listed in Table B.1. No test needs to be performed according to 5.16.4 if the chosen design is an accepted solution and the risk assessment proves the suitability for the boiler burner unit and the control algorithm interaction. If the risk assessment fails, further tests shall be required.	EN 303-5:2012 Art. 4.3.3.4	0	
Alternative verification of safety against back burning			
In case of any deviations regarding 4.3.3.2 to 4.3.3.4, the safety against back burning shall be verified according to the following procedures, combining a risk assessment including reliable tests of the alternative safety devices with reference to the criteria in 5.16.1. If:			
- no accepted solution is chosen, or;		0	
- the risk assessment ensures no suitability of a ac-	EN 303-5:2012	0	
cepted solution for the boiler design, or; - the accepted solutions against back burning are not	Art. 4.3.3.5		
applicable (e.g. the suitability of constructional means or devices or the tightness criterion for certain boiler designs),		0	
further tests shall be performed (see 5.16.5). The test shall be documented by the third party laboratory in a report which includes the description of the test sample and the test installation, the way to perform the back burning test, the test conditions and the test results.			
Safety against fuel overload of the boiler or interruption			
in fuel supply During start up and continuous operation of the boiler with the fuel feed rate of the stoking device set at maximum capacity or interruption of the stoking device, no dangerous situation shall occur. The test at overload mode according to 5.16.2 may be omitted if a safety device, safety level C according to 4.3.1, prevents an overload mode. The boiler shall be equipped with a safety device that stops the fuel supply in the event that there is either insufficient or no combustion in the burner head. The test for interruption of fuel supply according to 5.16.2 may be omitted if a safety device, safety level B or C according to 4.3.1, is used. In the ignition phase, a safety device shall stop the fuel supply after a safety time which shall be declared by the manufacturer of the burner start up function, if there is no or insufficient combustion. A failure in the safety device to detect insufficient combustion shall not lead to a dangerous situation.	EN 303-5:2012 Art. 4.3.4	+	Class B 31-8951/E 31-8951/ EMC

Report 31-8951/T2 Page 19 of 54



Requirement	Requirement specification	Evaluation	Note
Safety against lack of air supply or insufficient combustion If the air supply includes fan assistance or adjustable devices to control the cross section of the air inlet, the tests according to 5.16.3 shall be performed. Neither a combination of a failure of the fan and the malposition of the adjustable devices nor the malposition of adjustable devices with separate actuators at the same time shall be taken into account. The CO concentration in the boiler shall not exceed 5 % volume	EN 303-5:2012 Art. 4.3.5	+	Less than 5% CO
Surface temperatures The surface temperature on the outside of the boiler (including the bottom and doors but not including the flue gas outlet and maintenance openings of natural draft boilers) shall not exceed the room temperature by more than 60 K when tested in accordance with 5.12. The requirement for the bottom is not applicable for instances when the manufacturer declares that the boiler is to be installed on a non-combustible base. When tested in accordance with 5.12, the surface temperature of operating levers and all parts which shall be touched by hand during operation of the boiler shall not exceed the room temperature by more than the following values: - 35 K for metals and similar materials; - 45 K for porcelain and similar materials.	EN 303-5:2012 Art. 4.3.6	+	
Leakage of the combustion system For boilers designed to operate with a positive pressure in the combustion chamber when tested in accordance with 5.6 at a test-pressure of 1,2 times the gas side resistance at nominal heat output, the leakage rate based on mass flow shall not exceed 2 % of the flue gas mass flow at the nominal heat output. The gas side resistance shall be determined with the fuel chamber filled to maximum capacity (as specified by the manufacturer). NOTE: For boilers designed to operate with negative pressure, the leakage rate measured according to 5.6 characterises the boiler.	EN 303-5:2012 Art. 4.3.7	+	
Temperature control and limiting devices	EN 303-5:2012 Art. 4.3.8		
General The control and safety devices described in the sections below as well as the appropriate installation options shall be provided for each boiler, depending on the type of firing system and the type of protection provided for the installations in which the boiler is to be fitted. The equipment required in each case shall be supplied by the boiler manufacturer along with the boiler. If equipment is not supplied, precise specifications shall be given in the installation instructions, in particular the limit values and time constants for the safety temperature limiter.	EN 303-5:2012 Art. 4.3.8.1	+	



Requirement	Requirement specification	Evaluation	Note
Temperature control and limiting devices for open vented systems When used in physically protected heating installations (the temperature is limited by installation pressure) the following equipment shall be provided, according to the requirements of EN 14597: — a temperature controller; — a safety temperature limiter (manual reset). The safety temperature limiter is not necessary in cases where the firing system is neither rapidly nor partly disconnectable. In these cases (e.g. for boilers without automatic force draft), the excess heat is dissipated in the form of steam through the open vented connection with the atmosphere.	EN 303-5:2012 Art. 4.3.8.2	+	
Temperature control and limiting devices for closed vented system When used in thermostatically protected heating installations, the firing system shall be either rapidly or partly disconnectable; and/or the heat or residual heat output not absorbed by the heating system shall be dissipated reliably using a safety heat exchanger or equivalent devices. Accordingly, a distinction is to be made between the following equipment variants, according to the requirements of EN 12828:			
 a) The firing system is rapidly disconnectable; the necessary equipment shall consist of: a temperature controller; a safety temperature limiter (manual reset). 		+	
 b) The firing system is partly disconnectable; the necessary equipment shall consist of: a temperature controller; a safety temperature limiter (manual reset); a thermal discharge safety device in accordance with 4.3.8.4 for dissipating the maximum heat output possible in the event of a malfunction; 	EN 303-5:2012 Art. 4.3.8.3	0	
 c) The heating system is not disconnectable and the nominal heat output is < 100 kW; the necessary equipment shall consist of: a temperature controller; a thermal discharge safety device in accordance with 4.3.8.4 for dissipating the maximum heat output possible in the event of a malfunction. 		0	
If the requirements are not fulfilled, the boiler shall be installed in an open vented system according to EN 12828.		0	

Report 31-8951/T2
Page 21 of 54



Requirement	Requirement specification	Evaluation	Note
Devices for dissipating excess heat	- opcomoderon	0	
The safety heat exchanger or other devices for dissipating			
excess heat shall ensure that a maximum boiler water tem-			
perature of 110 °C is not exceeded in accordance			
with 5.14. For this purpose, a thermal discharge safety de-			
vice shall be used such as an STW type Th according to EN			
14597, in combination with a heat exchanger integrated in			
the boiler. Admissible heat exchangers include storage or			
circulatory water heaters, provided they are designed and			
sized in such a way that the heat can be transferred without			
any additional auxiliaries and outside energy. Fixed integrat-			
ed circulatory water heaters cannot be used as operating			
water heaters but only as safety heat exchangers. Additional-			
ly, the following conditions shall be met			
 the thermal safety discharge device and the heat ex- 			
changer shall be adapted to the design and thermal			
properties of the boiler and be capable of reliably		0	
dissipating the maximum heat output possible in the	EN 303-5:2012		
event of malfunction or, in the case of partly discon- nectable heating systems, the residual heat output;	Art. 4.3.8.4		
· · ·			
 if a storage water heater is used as the heat ex- changer, it shall be designed so that it meets the 			
aforementioned condition at its maximum operating		0	
temperature;			
 in the case of safety heat exchangers used exclu- 			
sively to dissipate heat in the event of malfunctions,			
the thermal safety discharge device shall be fitted		o	
ahead of the heat exchanger in the cooling water in-			
let.			
Other solutions are not excluded provided they comply with			
the protection objectives and safety standards described			
above. In principle however, all devices for dissipating ex-			
cess heat are only admissible for			
 boilers without a disconnectable firing system with 		0	
rated heat outputs of maximum 100 kW,		U	
 boilers with a partly disconnectable firing system with 		0	
residual heat outputs of up to 100 kW.		U	
Heating boiler accessories	EN 303-5:2012		
	Art. 4.3.9		
General			
If the boiler is factory equipped with additional fittings which	EN 303-5:2012		
need to be serviced to ensure their correct operation and the	Art. 4.3.9.1	0	
safety of the boiler, the design shall ensure ease of access	'		
without requiring extensive dismantling work.			

Report 31-8951/T2 Page 22 of 54



Requirement	Requirement specification	Evaluation	Note
Electrical safety The electrical safety of the boiler and the interfaces (e.g. connectors) between control devices shall comply with EN 60335-2-102. The electrical safety of control devices shall comply either with EN 60335-2-102, with EN 60730-1 or its relevant part 2 or with the electrical requirements of the standards listed in Annex ZBB of EN 60335-2-102:2006. For abnormal operation as fault condition according to 19.11.2 f) of EN 60335-2-102:2006 (failure of integrated circuits), only output signals which cause only one malfunction in one actuator shall be considered as relevant. Combinations of output signals which cause malfunction in more than one actuator are not considered relevant in the sense of abnormal operation because it is unlikely that any hazardous situation can occur. The documentation of the electrical connections for the individual components shall be provided by means of an electrical wiring and connection diagram.	EN 303-5:2012 Art. 4.3.9.2	+	Class B 31-8951/E
Electromagnetic compatibility The EMC requirements shall be fulfilled in accordance with EN 61000-6-2 and EN 61000-6-3. For this testing, it is permissible to use an adapted version of the boiler software for simulating boiler operation.	EN 303-5:2012 Art. 4.3.9.3	+	31-8951/ EMC

Note:

- + Compliant
- Non-compliant
- 0 Not applicable
- x Not assessed

Evaluation drafted by: Ing. Michal Havlů

Date:

10/2012 Signed:

Person responsible for the evaluation:

Ing. Stanislav Buchta

Date:

10/2012 Signed:



Requirement assessed:

Performance requirements

Requirement specification:

EN 303-5:2012

Art. 4.4, 4.4.1, 4.4.2, 4.4.3, 4.4.4, 4.4.5, 4.4.6, 4.4.7

Sample assessed:

PelTec - lambda 12, PelTec - lambda 48

Evaluation results:

see the following Table

Requirement	Requirement specification	Evaluation	Note
General The following performance requirements shall be assessed in tests using the appropriate test fuel(s) specified in Table 7. These shall be selected to represent the recommended fuel(s) which it is claimed the boiler can burn. NOTE The nominal heat output and the heat output range might vary depending on the fuel. The requirements for the boiler efficiency and the emission limits are divided into 3 classes. To meet the class requirements, all the efficiency and emission limits of that class shall be fulfilled.	EN 303-5:2012 Art. 4.4.1	+	
Boiler efficiency The boiler efficiency, when tested in accordance with 5.7, 5.8 and 5.10, shall not be less than the formula shown in Figure 1 for the nominal heat output. For boilers above 100 kW, the requirement for class 4 is given at 84 % and class 5 is given at 89 %. For boilers above 300 kW, the requirement of class 3 is given at 82 %.	EN 303-5:2012 Art. 4.4.2	+	
Flue gas temperature For boilers which operate with a flue gas temperature below 160 K and above room temperature at nominal heat output, the boiler manufacturer shall make recommendations re- garding the flue installation in order to ensure sufficient draught and to prevent the chimney sooting up and conden- sation.	EN 303-5:2012 Art. 4.4.3	+	Less than 160K
Draught The manufacturer shall specify the minimum draught at the flue gas outlet of the boiler needed for correct operation of the boiler. Where the manufacturer gives no detailed values, the figures according to Table B.2 of EN 13384-1:2002+A2:2008 shall apply.	EN 303-5:2012 Art. 4.4.4	+	
Combustion period The combustion period for hand-stoked boilers at nominal heat output shall be stated by the manufacturer and shall be at least: — 2 hours for biogenic and other solid fuels; — 4 hours for fossil fuels.	EN 303-5:2012 Art. 4.4.5	0	

Report 31-8951/T2 Page 24 of 54



Requirement	Requirement specification	Evaluation	Note
Minimum heat output For automatically stoked boilers, the minimum heat output shall not exceed 30 % of the nominal heat output. This requirement on limiting the maximum heat output shall be achieved automatically by a control device.		+	
The control of the fuel and/or the air supply may be either continuous or intermittent. For manually stoked boilers where the manufacturer specifies that the boiler shall be connected to an accumulator.		+	
fies that the boiler shall be connected to an accumulator tank, the minimum continuous heat output can be greater than 30 % of nominal heat output, provided that the manufacturer specifies in the technical document.		0	Less than 30% Qn
The boiler plate shall state the minimum accumulator tank volume.		0	
Manually stoked boilers do not require testing at minimum heat output if the manufacturer claims that they shall always be connected to accumulator tank. The following applies as a reference for the minimum accumulator tank volume:	EN 303-5:2012 Art. 4.4.6	0	
$V_{\text{Sp}} = 15 T_{\text{B}} \times Q_{\text{N}} \left(1 - 0.3 \frac{Q_{\text{H}}}{Q_{\text{min}}} \right)$			
where	·		
V_{Sp} is the accumulator tank volume, in litres;			
Q _N is the nominal heat output, in kilowatts;			
$T_{\rm B}$ is the burning period, in hours;			
Q _H is the heating load of the premises, in kilowatts;			
Q_{min} is the minimum heat output, in kilowatts. For heating boilers using several allowable fuels, the tank size shall be based on the fuel which requires the largest accumulator tank. The minimum volume of the accumulator tank shall be 300 l.		+	
Emission limits			
Combustion shall be of low-emission. This requirement shall be satisfied if the emission values shown in Table 6 are not exceeded when operating at nominal heat output or, in the case of boilers with heat output range, when operating at nominal heat output and minimum heat output, in accordance with 5.7, 5.9 and 5.10.	EN 303-5:2012 Art. 4.4.7	+	

Note:

+ Compliant

0 Not applicable

- Non-compliant

x Not assessed

Evaluation drafted by: Ing. Michal Havlů

Date: 10/2012

Signed:

Person responsible for the evaluation:

Ing. Stanislav Buchta

Date:

10/2012 Signed:



Requirement assessed: Marking

Requirement specification: EN 303-5:2012 Art. 7, 7.1, 7.2, 7.3

Sample assessed: PelTec - lambda 12, PelTec - lambda 48

Evaluation results: see the following Table

Requirement	Requirement specification	Evaluation	Note
Marking	EN 303-5:2012		
	Art. 7		
General	EN 000 5 0040		
Each heating boiler shall have a data plate. The boiler data	EN 303-5:2012	+	
plate shall be written in the language of the country of destination and be affixed in an accessible spot.	Art. 7.1		
Information on the boiler plate			
The boiler plate shall contain at least the following infor-			
mation:			
a) name and company domicile of the manufacturer and, where available, the manufacturer's symbol;	EN 303-5:2012 Art. 7.2	+	
 b) trade designation, type under which the boiler is mar- keted; 		+	
 c) production number and year of construction (coding is permissible at the manufacturer's discretion); 		+.	
 d) nominal heat output and heat output range in kilowatts for each type of fuel; 		+	
e) boiler class regarding each fuel type that was tested;		+	
f) maximum allowable operating pressure, in bar;		+	
g) maximum allowable operating temperature, in degrees Celsius;		+	
h) water content, in litres;		+	
i) electrical connection (V, Hz, A) and wattage, in watts;		+	
 j) the fuel class according to Clause 1 and for fuels of class E the tested fuel. 		+	
Boiler plate requirements			
The material and labelling used for the plate shall be durable. The labelling shall be abrasion-proof. Under normal operating conditions, the plate shall not discolour so as to make its information difficult to read. Self-adhesive plates should not become detached as a result of moisture and temperature.	EN 303-5:2012 Art.7.3	+	

Note:	+	Compliant	0	Not applicable
	-	Non-compliant	Χ	Not assessed

Evaluation drafted by: Ing. Michal Havlů Date: 10/2012 Signed:

Person responsible for the evaluation:

Ing. Stanislav Buchta Date: 10/2012 Signed:



Requirement assessed: Technical documentation, supplied with boiler

Requirement specification: EN 303-5:2012

Art. 8, 8.1, 8.2, 8.3, 5.16.1

Sample assessed: PelTec - lambda 12, PelTec - lambda 48

Evaluation results: see the following Table

Requirement	Requirement specification	Evaluation	Note
Technical documentation, supplied with boiler	EN 303-5:2012 Art. 8		
General For each boiler, the documents listed below shall be made available in the language of the boiler's country of destination; the documents specified under 8.2 and 8.3 shall be enclosed with every boiler	EN 303-5:2012 Art. 8.1	+	
Technical information and installation instructions These documents shall contain at least the following indications: a) necessary draught, in millibars; b) water content, in litres; c) exhaust gas temperature at nominal heat output and minimum heat output, in degrees Celsius; d) exhaust mass flow at nominal heat output and at minimum heat output, in kilograms per second; e) flue pipe diameter, in millimetres; f) water-side resistance, in millibars; g) nominal heat output and heat output range, in kilowatts; h) boiler class; i) combustion period in hours at QN; j) setting range for the temperature controller, in degrees Celsius; k) minimal return temperature at boiler return tapping, in degrees Celsius; l) fuel type and water content as well as fuel size and detail information according to Table 7 for fuels type E resp. e; m) filling chamber capacity in litres and filling opening dimensions, in millimetres; n) necessary accumulator storage, in litres if Qmin > 0,3 QN; o) auxiliary power requirement at QN and Qmin, in watts; p) stand by power, in watts; q) cold water temperature and pressure for safety heat exchanger, in bars; r) electrical connections including appliance and mainswitch-off; s) whether the heating appliance is running with or without using a fan; t) whether the heating appliance is working under over pressure or under pressure at flue gas outlet; u) whether the heating appliance is working under condensing or non-condensing conditions;	EN 303-5:2012 Art. 8.2	+ + + + + + + + + + 0 + + + + + +	Enclosed technical documentation.

Report 31-8951/T2 Page 27 of 54




Requirement	Requirement specification	Evaluation	Note
v) information about the boiler's emission of airborne noise, the method to measure the airborne noise level and the possibilities of means of reducing the noise emission of the boiler.		+	31-8951/M
NOTE: Noise measurements should be made according to EN 15036-1.			
Furthermore, the installation instructions shall contain information concerning:			
w) the on-site assembly of the boiler (if necessary) and the required water pressure test as per 5.4.2 or 5.5.2.2;		+	
x) the installation;		+	
y) the commissioning, with information on the boiler output to be set in the output range;		+	
z) instructions on the location and fitting of the sensors for the control, display and safety equipment.		+	
In addition, the technical information and installation instructions shall contain general references to the standards and regulations to be observed on the safety equipment of the	EN 303-5:2012		
 installation: take care of installed ventilations systems in the same heating room; 	Art. 8.2	+	
 take care there is sufficient amount of clean (i.e. uncontaminated) combustion air; 		+	
 measuring points should be self-locking and thigh; 		+	
- emission control after first installation;		+	
 verbal instruction by a competent person before first using; 		+	
take care of the correct storage of the used fuels;regularly checks if the heating appliance is in good		+	
condition;			
 take care of the correct dimensioning of the System; take care of the correct dimensioning of the chimney including the correcting fluoring. 		+	
 including the connecting flue pipe; take care of the necessary distances to combustible materials, if required; 		+	
- require a shielding construction, if necessary;		+	
 take care of the necessary minimum distance to walls and ceilings (related to cleaning). 		+	

Report 31-8951/T2 Page 28 of 54



Requirement	Requirement specification	Evaluation	Note
 Operating instructions The operating instructions shall contain references to: the operation of the boiler, stoking and opening doors without risk; cleaning and cleaning intervals, including the equipment required for the cleaning operations; measures to be taken in the event of malfunction; the reasons for recommending a regular, competent maintenance service and the necessary maintenance intervals; the type of fuel and water content and the fuel size (with the direction of the layers in the case of wood logs); the maximum filling height for fuel in the filling chamber; the nominal combustion period for fuel types at nominal 	EN 303-5:2012 Art. 8.3	+ + + + + +	
heat output. Other documents (brochures, etc.) shall not contain any information that is in contradiction with that of the operating instructions.		·	
Check of the safety and risk assessment A risk analysis shall be performed by the manufacturer according to EN ISO 12100. "Force majeure risks" shall not be taken into consideration. Completeness, correctness and plausibility of the risk analysis of the manufacturer shall be verified by a third party. The verification does not generally require testing. If tests are performed, the following conditions shall be applied. a) Adjust the firing so that it corresponds to the nominal heat output QN of the boiler, a steady state condition shall be reached and the outlet pressure at the flue gas section shall be according to the nominal heat output setting. b) For manual stoked boilers, the boiler shall be refuelled after reaching steady state with a full batch before starting the test. The verification of the risk analysis can be done on the basis of one or more of the following: implementation of accepted solutions according to this standard; implementation of safety functions with verification of the shut-off function; check of the characteristics of the boiler at normal operation and in the case of failures; relevant references to other standards or associated test results. The risk analysis shall at least provide risk assessments for the following tasks and take into account possible failures in the components of the fuel supply, the air supply, the combustion and combustion control, the flue gas exit, the heat dissipation, fire prevention and the risk of injuries of persons.	EN 303-5:2012 Art. 5.16.1	+	



Requirement	Requirement specification	Evaluation	Note
 The following risks shall be evaluated in detail: c) fuel feed operation continuously at maximum speed, fuel overload; d) feed rate too low; e) loss of air supply; f) loss of power; g) unstable combustion chamber pressure; h) unclosed doors and openings within the boiler or the stoking device; i) opened integral fuel hopper; j) empty integral fuel hopper; k) ignition failure during start up; l) check of the strategy for safety against back burning; m) safety check regarding effect of emptiness or a blockage of the stoking device; n) voltage variation; o) leakage of combustion products (e.g. flue gas fan failure, power loss, pressurized combustion chamber); p) lockout and restart; q) electric safety (documents and certificates have to be provided); r) risk of injuries of persons. NOTE Additional tests are recommended.	EN 303-5:2012 Art. 5.16.1	+	
NOTE Additional tests are recommended.	<u> L</u>		

Note:

Compliant

0

Not applicable Non-compliant

Not assessed

Evaluation drafted by: Ing. Michal Havlů

Date:

10/2012

Signed:

Person responsible for the evaluation:

Ing. Stanislav Buchta

Date:

Signed: 10/2012

v. 3.00

Accredited test

number:

1001.1* Test title: Strength and tightness of pressurized components

Test method:

EN 303-5:2012 Art. 5.4, 5.4.1, 5.4.2

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evaluation	Note
Pressure test for boilers of sheet or sheet metal of			
non-ferrous metal	Art. 5.4		
Tests to be carried out before production The type test pressure is $2 \times PS$ using hydraulic pressure where PS is the maximum permissible operating pressure. The test period shall be at least 10 min and if it is to apply to a range of boilers, the test shall be carried out on at least 3 boiler sizes (smallest, medium, and largest size). No leakage or noticeable permanent deformation shall occur during the test.		+	Enclosed technical documentation.
A record shall be made of the test, including the following details: - exact description of the boiler tested by stating the draw-	EN 303-5:2012 Art. 5.4.1		
ing number;		+	
- test pressure in bar and duration of the test;		+	
- test result;		+	
- place and date of the test, including the names of persons carrying out the test.		+	
The test report shall be signed by, as a minimum, the works tester responsible and one witness.		+	
Test during production Each boiler shall be tested during the production and the test pressure shall be at least 1.43 × <i>PS</i> .	EN 303-5:2012 Art. 5.4.2	+	

Test evaluation:

No leakages or visible permanent deformations appeared during the test.

Tested by:

Ing. Michal Havlů

Date: 10/2012

Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

Signed



Accredited test

1003* Test title: Surface temperature test

number:

Test method:

EN 303-5:2012 Art. 5.12, 5.16.4, 4.3.6

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evaluation	Note
Surface temperature The mean surface temperature shall be measured at nominal heat output. In order to do this, a minimum of 5 points on each boiler surface shall be measured. Under the same conditions, the critical temperatures (e.g. boiler doors, operating levers) shall be measured.	EN 303-5:2012 Art. 5.12	+	
The surface temperature on the outside of the boiler (including the bottom and doors but not including the flue gas outlet and maintenance openings of natural draft boilers) shall not exceed the room temperature by more than 60 K when tested in accordance with 5.12. The requirement for the bottom is not applicable for instances when the manufacturer declares that the boiler is to be installed on a non-combustible base. When tested in accordance with 5.12, the surface temperature of operating levers and all parts which shall be touched by hand during operation of the boiler shall not exceed the room temperature by more than the following values: - 35 K for metals and similar materials; - 45 K for porcelain and similar materials.	EN 303-5:2012 Art. 4.3.6	+	
Resistance to thermal conductance Temperature measurement shall be performed on the surface of the stoking device at the place next to the fuel line but within a maximum distance which shall be less than 1 m against the feeding direction from the inner wall of the combustion chamber. For boilers with integrated hopper, the temperature measurement shall be performed on the surface of the stoking device at the place next to the integrated hopper but within a maximum distance which shall be less than 1 m against the feeding direction from the inner wall of the combustion chamber. In addition, the highest surface temperature of the hopper shall be measured.	EN 303-5:2012 Art. 5.16.4	+	

Measurement results: PelTec - lambda 12

Average temperatures of boiler walls, doors and covers (⁰ C):				
Fuel type Pellets – C1				
Front wall	28			
Rear wall	30			
Right wall	29			
Left wall	30			
Upper wall	34			
Lower wall (A base was used, non-combustible material)	51			
Temperatures of control elements(⁰ C):				
Ash chamber door handle – metal 30				
El. control panel – plastic	30			
Temperature of fuel chamber and stoking elements (⁰ C):				
Inner face of fuel chamber	30			
Temperature of fuel line tube (Screw conveyor – flange)	55			

Measurement results: PelTec - lambda 48

Average temperatures of boiler walls, doors and covers (°C):				
Fuel type	Pellets – C1			
Front wall	28			
Rear wall	31			
Right wall	31			
Left wall	31			
Upper wall	38			
Lower wall (A base was used, non-combustible material)	57			
Temperatures of co	ntrol elements(^º C):			
Ash chamber door handle – metal	30			
El. control panel – plastic	31			
Temperature of fuel chamber	and stoking elements (°C):			
Inner face of fuel chamber	32			
Temperature of fuel line tube (Screw conveyor – flange)	58			

Measurement uncertainty: 2 °C for temperatures within the range of (0 ÷ 250) °C

"The above-specified extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient, k=2, corresponding to the coverage certainty of 95% as regards standard classification. The uncertainties do not reflect the impact of sample taking and lack of homogeneity. The standard uncertainty was determined in accordance with Document EA 4/02."

<u>Test evaluation:</u> Prescribed values for temperature rise have not been exceeded.

Tested by: Ing. Michal Havlů Date: 10/2012 Signed: Reviewed by: Ing. Stanislav Buchta Date: 10/2012 Signed:



Accredited test

1004.1* Test title: **Test of heat output, input and efficiency**

number:

1004.2*

Test of combustion product temperature

Test method:

EN 303-5:2012

Art. 4.4.2, 4.4.3, 5.7 to 5.10

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Average measured and calculated values (solid fuels):

est: I.		II.	
Boiler type:		PelTec - lambda 12	
Output tested:		Nominal	Minimum
Fuel type:		Pellets - C1	
Combustion period, (manual/automatic) stoking		Minimally	y 6 hours
Nominal heat output (specified by manufacturer)	[kW]	12	12
Flue gas temperature	[°C]	93.3	71.6
Fuel mass added	[kg/hour]	2.840	0.832
Flow temperature	[°C]	65.6	82.9
Return temperature	[°C]	84.7	86.1
Temperature of the entering cold water	[°C]	20.0	21.4
Cooling water flow rate	[m³/hour]	0.5450	0.8841
Draught	[Pa]	10	8
Ambient temperature	[°C]	24.7	26.0
Relative air humidity	[%]	52.1	52.1
Barometric pressure	[kPa]	99.103	99.103

Flue gas analysis:

Test (period of burning):		1.	II.
Oxygen, O ₂	[%]	10.65	12.93
Carbon dioxide, CO ₂	[%]	9.18	7.13
Carbon monoxide, CO	[ppm]	88	181
Higher hydrocarbons, THC/OGC	[ppm]	3	5
Nitrogen oxides, NO _x	[ppm]	84	59

Report 31-8951/T2 Page 35 of 54



Auxiliary combustion values (solid fuels):

Test (period of burning):		1.	11.
Stoichiometric oxygen volume	[m³/kg]	0.919	0.927
Stoichiometric air volume	[m³/kg]	4.376	4.415
Stoichiometric volume of dry combustion products	[m³/kg]	4.319	4.359
Maximum content of CO ₂	[%]	19.94	19.95
Stoichiometric air multiple	[-]	2.02	2.58
Volume of dry combustion products, actual	[m ³ /kg]	9.375	12.157
Content of H ₂ O in combustion air	[m³/kg]	0.145	0.202
Content of H ₂ O in combustion products	[m ³ /kg]	0.885	0.943

Calculated values - thermal overview

Test (period of burning):		1.	II.
Loss of sensible heat of combustion products (chimney)	[%]	5.6	4.7
Loss of gas underburning	[%]	0.1	0.2
Loss of mechanical underburning	[%]	1.0	0.1
Loss of heat transfer into environment	[%]	1.6	4.3
Total loss	[%]	8.2	9.2
Heat input	[kW]	13.6	4.0
Heat output	[kW]	12.3	3.6
Uncertainty of determining heat output	[kW]	0.5	0.2
Efficiency – direct method	[%]	90.4	90.2
Output / nominal output	[%]	102.5	29.8

At nominal output, when burning **pellets – C1**, the boiler efficiency meets the requirements applicable to **Class 5** as per EN 303-5:2012, Figure 1.

The measured heat output is within the \pm 8% tolerance;

Boiler Class 5;

Test evaluation:

At nominal output, combustion product temperature is less than 160 K above the ambient temperature;

When burning wood pellets, the period of burning is longer than 6 hours; The minimum heat output is less than 30% of nominal heat output.

Report 31-8951/T2 Page 36 of 54

Z

PelTec - lambda 12

Electricity consumption

During the tests, the electrical consumption shall be determined according to EN 15456.

The values for maximum consumption, for stand-by, nominal heat output and minimum heat output shall be stated in the test report. For boilers with automatic feeding systems (fuel line), the electrical consumption of the boiler and the fuel line shall be determined and stated separately.

The average electrical power consumption during stand by shall be measured for a minimum duration of 10 min and shall be stated in watts. In cases where control operations influence the intrinsic energy consumption, a longer duration might be necessary.

Maximum electrical input	1050 W
Electrical input at nominal heat output	40 W
Electrical input at minimum heat output	25 W
Electrical input for STAND BY mode	5 W
Maximum electrical input for fuel supply (fuel line)	35 W
Maximum electrical input for ignition system	1010 W

Test results:

Average measured and calculated values (solid fuels):

Test:		I.	II.
Boiler type:		PelTec - lambda 48	
Output tested:		Nominal	Minimum
Fuel type:		Pellets - C1	
Combustion period, (manual/automatic) stoking		Minimally 6 hours	
Nominal heat output (specified by manufacturer)	[kW]	48	48
Flue gas temperature	[°C]	103.5	71.6
Fuel mass added	[kg/hour]	11.30	3.07
Flow temperature	[°C]	62.1	68.8
Return temperature	[°C]	82.0	84.7
Temperature of the entering cold water	[°C]	18.6	19.6
Cooling water flow rate	[m³/hour]	2.121	0.718
Draught	[Pa]	10	8
Ambient temperature	[°C]	21.9	25.6
Relative air humidity	[%]	64.6	64.6
Barometric pressure	[kPa]	99.105	99.112

Flue gas analysis:

: rae gae arrary ere:			
Test (period of burning):		I.	II.
Oxygen, O ₂	[%]	7.78	10.88
Carbon dioxide, CO ₂	[%]	11.67	9.10
Carbon monoxide, CO	[ppm]	47	58
Higher hydrocarbons, THC/OGC	[ppm]	0	1
Nitrogen oxides, NO _x	[ppm]	97	74

Report 31-8951/T2 Page 37 of 54

Auxiliary combustion values (solid fuels):

Test (period of burning):		1.	II.
Stoichiometric oxygen volume	[m ³ /kg]	0.908	0.905
Stoichiometric air volume	[m³/kg]	4.322	4,311
Stoichiometric volume of dry combustion products	[m³/kg]	4.265	4.255
Maximum content of CO ₂	[%]	19.93	19.92
Stoichiometric air multiple	[-]	1.58	2.06
Volume of dry combustion products. actual	[m³/kg]	7.280	9.305
Content of H ₂ O in combustion air	[m³/kg]	0.118	0.191
Content of H ₂ O in combustion products	[m³/kg]	0.858	0.932

Calculated values - thermal overview

Test (period of burning):		l.	II.
Loss of sensible heat of combustion products (chimney)	[%]	5.3	3.7
Loss of gas underburning	[%]	0.0	0.0
Loss of mechanical underburning	[%]	2.1	2.4
Loss of heat transfer into environment	[%]	1.4	2.6
Total loss	[%]	8.8	8.7
Heat input	[kW]	54.5	14.8
Heat output	[kW]	49.3	13.4
Uncertainty of determining heat output	[kW]	2.1	0.6
Efficiency – direct method	[%]	90.5	90.8
Output / nominal output	[%]	102.7	28.0

At nominal output, when burning pellets - C1, the boiler efficiency meets the requirements applicable to Class 5 as per EN 303-5:2012, Figure 1.

The measured heat output is within the \pm 8% tolerance;

Boiler Class 5;

Test evaluation:

At nominal output, combustion product temperature is less than 160 K above the ambient temperature;

When burning wood pellets, the period of burning is longer than 6 hours;

The minimum heat output is less than 30% of nominal heat output.

PelTec - lambda 48

Electricity consumption

During the tests, the electrical consumption shall be determined according to EN 15456.

The values for maximum consumption, for stand-by, nominal heat output and minimum heat output shall be stated in the test report. For boilers with automatic feeding systems (fuel line), the electrical consumption of the boiler and the fuel line shall be determined and stated separately.

The average electrical power consumption during stand by shall be measured for a minimum duration of 10 min and shall be stated in watts. In cases where control operations influence the intrinsic energy consumption, a longer duration might be necessary.

Maximum electrical input	1060 W
Electrical input at nominal heat output	50 W
Electrical input at minimum heat output	35 W
Electrical input for STAND BY mode	5 W
Maximum electrical input for fuel supply (fuel line)	35 W
Maximum electrical input for ignition system	1010 W

Fuel analysis

ruei alialysis								
Fuel type	Pellets – C1							
Analytical indicator	Symbol	Unit	Value	Uncertainty				
Heat of combustion	Q _s	[MJ/kg]	18.48	0.14				
Caloric value	Q_{j}	[MJ/kg]	16.89	0.14				
All water in original condition	W ^r t	[% by weight]	7.42	0.01				
Ash	Α	[% by weight]	0.37	0.02				
Carbon	С	[% by weight]	46.96	0.25				
Hydrogen	Н	[% by weight]	6.43	0.10				
Nitrogen	N	[% by weight]	0.12	0.10				
Sulphur	S	[% by weight]	0.017	0.001				
Chlorine	Cl	[% by weight]	0.013	0.002				
Oxygen – calculation for 100%	0	[% by weight]	38.67					
Conversion factor f _{emis} for emissions in [mg/m³] to [mg/MJ]	f_{emis}	[-]	0.26622					

Note: Sample in original condition

Measurement uncertainty: Specified in Measurement results

"The above-specified extended measurement uncertainties are calculated as a factor of the measurement uncertainty and the extension coefficient, k=2, corresponding to the coverage certainty of 95% for standard classification. The uncertainties do not reflect the impact of sample taking and lack of homogeneity. The standard uncertainty was determined in accordance with Document EA 4/02."

Tested by:	Ing. Michal Havlů	Date:	10/2012	Signed:

Reviewed by: Ing. Stanislav Buchta Date: 10/2012 Signed:



Accredited test

number:

1005.1* Test title: Combustion efficiency test - emissions

Test method:

EN 303-5:2012

Art. 4.4.7, 5.7.3, 5.7.4, 5.9, 5.10.4

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Requirement	Requirement specification	Test evaluation	Note
Emission limits Combustion shall be of low-emission. This requirement shall be satisfied if the emission values shown in Table 6 are not exceeded when operating at nominal heat output or, in the case of boilers with heat output range, when operating at nominal heat output and minimum heat output, in accordance with 5.7, 5.9 and 5.10.	EN 303-5:2012 Art. 4.4.7	+	

Table 6

		Nominal heat					Emission lim	its				
		output		CO			OGC/THC			Dust		
Stoking	Fuel	-	mg/m³ at 10% O₂									
		kW	Class	Class	Class	Class	Class	Class	Class	Class	Class	
		N. C.	3	4	5	3	4	5	3	4	5	
Manual	Biogenic	≤ 50	5000			150						
		> 50 ≤ 150	2500		,	100			150			
		> 150 ≤ 500	1200	1200	700	100	50	50	30		75	60
	Fossil	≤ 50	5000	1200	700	150	- 50	30			/5	
		> 50 ≤ 150	2500			100			125			
		> 150 ≤ 500	1200			100						
Automatic	Biogenic	≤ 50	3000			100						
		> 50 ≤ 150	2500			80			150			
		> 150 ≤ 500	1200	1000	500	80	20	20				
	Fossil	≤ 50	3000	1000	500	100	30			60	40	
		> 50 ≤ 150	2500			80			125			
		> 150 ≤ 500	1200			80						

NOTE 1: The dust values in this Table are based on the experience of the gravimetric filter method. The method used needs to be referred to in the test report. The particulate matter emission measured according to this European Standard does not include condensable organic compounds which may form additional particulate matter when the flue gas is mixed with ambient air. The values are therefore not directly comparable with values measured by dilution tunnel methods. Neither can they be directly translated into ambient air particulate concentrations.

NOTE 2: Additional test methods and emission limits which apply in some countries are given in the A-Deviations in Annex C.

^a Referred to dry exit flue gas, 0 °C, 1013 mbar.

^b Boilers of class 3 for type E-fuels according to 1.2.1 or e-fuels according to 1.2.3 in this Table and marked with the classification E-fuels and e-fuels do not need to fulfil the requirements for the dust emissions. The actual value shall be stated in the technical documentation and shall not exceed 200 mg/m3 at 10 % O2.

Measurement results: PelTec - lambda 12

	Average values									
Boiler		Measured values						nverted va	lues O ₂ =	10%
	CO₂ [%]	CO [ppm]	OGC/THC [ppm]	NO _x [ppm]	Dust [mg/m³]		OGC/THC [mg/m ³]	NO _x [mg/m³]	Dust [mg/m³]	
Nominal	10.65	9.18	88	3	84	26	116	5	184	28
Minimum	12.93	7.13	155	4	58	15	268	3	164	21

Test evaluation:

PelTec - lambda 12 meets at nominal and minimum output the emission requirements for Class 5 as per EN 303-5:2012 Table 6.

Measurement results: PelTec - lambda 48

					es					
Boiler			Meas	ured values	Co	nverted va	lues O ₂ =	10%		
output	O ₂	CO ₂	CO	OGC/THC	NO _x	Dust		OGC/THC	^ ~	Dust
	[%]	[%]	[ppm]	[ppm]	[ppm]	[mg/m ³]	[mg/m³]	[mg/m³]	[mg/m³]	[mg/m ³]
Nominal	7.78	11.67	47	0	97	30	49	0	165	25
Minimum	10.88	9.10	58	1	74	24	79	0	166	26

Test evaluation:

PelTec - lambda 48 meets at nominal and minimum output the emission requirements for Class 5 as per EN 303-5:2012 Table 6.

Tested by:

Ing. Michal Havlů

10/2012 Date:

Signed:

Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

Signed:



Accredited test

1004.1* Test title: Test of heat capacity, input and efficiency

number:

1005.1*

Combustion efficiency test - emissions

EN 303-5:2012

Test method:

Annex C,

Deviation from Austria, C.2.2, C.2.3

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement		Requirement specification	Test evaluation
Boiler efficiency for nominal hea output	t output and minimum heat		
Boiler	Minimum efficiency		
Heating boilers for solid fuels	75 %		+
a) manually loaded	:	EN 202 5:2012	
up to 10 kW	79 %	EN 303-5:2012	
>10 to 200 kW	(71.3 + 7.7 log Pn) %	Annex C, Deviation from	
>200 kW	89 %	Austria, C.2.2	
a) automatically loaded		71001110, 0.2.2	
up to 10 kW	80 %		+
>10 to 200 kW	>10 to 200 kW (72.3 + 7.7 log Pn) %		+
>200 kW	90 %		
NOTE Pn is the nominal heat of	output (Qn in this standard).		

Require	ment			Requirement specification	Test evaluation	
Emissio	n limits					
Small bu	rners used for	solid fuels a	utomatically	loaded		
		Emission mg/N				
Parameter	Wooden pellets Room heaters	Wooden pellets Central heaters	Other wooden fuels	Other stand- ardised biogenous fuels	EN 303-5:2012 Annex C,	
СО	500ª	250 ^a	250 ª	500 ª	Deviation from Austria, C.2.3	
NO _x	150	150	150	300	Ααστια, Ο.Σ.σ	
OGC/THC	30	30	30	30		+
Dust	50	40	50	60		

The limit value can be exceeded by 50 % during partial load operation at 30 % of nominal heat output.

Measurement results: PelTec - lambda 12

Boiler output	Minimum required efficiency	Measured efficiency
Nominal	90.6	90.4
Minimum	80.6	90.2

Measurement results: PelTec - lambda 48

Boiler output	Minimum required efficiency	Measured efficiency
Nominal	85.2	90.5
Minimum	00.2	90.8

Test evaluation:

The measured efficiency of PelTec - lambda 12, PelTec - lambda 48 is **higher** than required.

Measurement results: PelTec - lambda 12

					Average	e values				
Boiler out-		Measured values			C	onverted v	alues O ₂ =0%)		
put	O ₂ [%]	CO [ppm]	NO _x [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/ M J]	NO _X [mg/MJ]	OGC/THC [mg/MJ]	Dust [mg/MJ]	
Nominal	10.65	88	84	3	26	56	89	1	13	
Minimum	12.93	157	59	5	15	131	49	4	10	

Measurement results: PelTec - lambda 48

		Average values								
Boiler out-		Measured values				Converted values O ₂ =0%				
put	O ₂ [%]	CO [ppm]	NO _x [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/MJ]	NO _X [mg/MJ]	OGC/THC [mg/MJ]	Dust [mg/MJ]	
Nominal	7.78	47	97	0	30	23	79	0	12	
Minimum	10.88	58	74	1	24	37	48	0	12	

Test evaluation:

The measured emission values for PelTec - lambda 12, PelTec - lambda 48 do not exceed prescribed values.

Tested by:

Ing. Michal Havlů

Date: 10/2012

Signed:

Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

Signed:

v. 3.00



Accredited test

1004.1* Test title: Test of heat output, input and efficiency

number:

1005.1*

Combustion efficiency test - emissions

EN 303-5:2012

Test method:

Annex C,

Deviation from Denmark, C.4.1, C.4.2

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requirement specification	Test evaluation	
Boiler efficiency			
According to the Danish Clause 8.5.1.4, Sub-clause 7, or biomass shall have an eff in EN 303-5.	Deviation from	Pellets – C1	
Minimum efficiency	(67 + 6 log Qn) %	Denmark, C.4.1	+
For boilers above 300 kW, the 300 kW shall be used.	requirement corresponding to		

Requiren	nent					Requirement specification	Test evaluation		
Emission	limits								
_	•	Danish EPA Statut Class 3 (or higher)	•						
			Emi	ssion limi	ts ^a				
Stoking	Fuel	Nominal heat output	со	OGC/ THC	Dust		Pellets – C1		
Stoking Tuel	i uei		mg/m³ at 10% O₂ Class						
		kW				EN 202 5:2012			
				3		EN 303-5:2012			
	Biogen-	≤ 50	5000	150		Annex C,			
	ic	> 50 to 150	2500	100	150	150	150	Deviation from	
Manual		> 150 to 300	1200	450		Denmark, C.4.2			
	Fossil	≤ 50 > 50 to 150	5000 2500	150	125	Deninark, 0.4.2			
	FUSSII	> 150 to 150	1200	100	125				
	 	≤ 50	3000	100			+		
	Bio-	> 50 to 150	2500		150		•		
	genic	> 150 to 300	1200	- 80					
Automatic Fossil	≤ 50	3000	100						
	> 50 to 150	2500		125					
FOSSII		> 150 to 300	1200	80	125				

Measurement results: PelTec - lambda 12

Boiler output	Minimum required efficiency	Measured efficiency
Nominal	73.5	90.4
Minimum	73.5	90.2

Measurement results: PelTec - lambda 48

Boiler output	Minimum required efficiency	Measured efficiency
Nominal	77 1	90.5
Minimum] //.1	90.8

Test evaluation:

The measured efficiency of PelTec - lambda 12, PelTec - lambda 48 is **higher** than required.

Measurement results: PelTec - lambda 12

		A Committee Committee	A۱	erage emis	ion values			
Boiler		Measured values			Converted values O ₂ =10%			
output	O ₂ [%]	CO [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/m³]	OGC/THC [mg/m ³]	Dust [mg/m³]	
Nominal	10.65	88	3	26	116	5	28	
Minimum	12.93	155	4	15	268	3	21	

Measurement results: PelTec - lambda 48


	Average emission values									
Boiler		Measured values				Converted values O ₂ =10%				
output	O ₂ [%]	CO [ppm]	OGC/THC [ppm]	Dust [mg/m³]	CO [mg/m³]	OGC/THC [mg/m ³]	Dust [mg/m³]			
Nominal	7.78	47	0	30	49	0	25			
Minimum	10.88	58	1	24	79	0	26			

Test evaluation:

The measured emission values for PelTec - lambda 12, PelTec - lambda 48 **do not exceed** prescribed values.

Tested by: Ing. Michal Havlů Date: 10/2012 Signed:

Reviewed by: Ing. Stanislav Buchta Date: 10/2012 Signed:



Accredited test

1004.1* Test title: Test of heat output, input and efficiency

number:

1005.1*

Combustion efficiency test - emissions

EN 303-5:2012

Test method:

Annex C,

Deviation from Germany, C.5.1, C.5.2

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	t			Requirement specification	Test evaluation	
Emission lim	nits					
Table 7 – Em	ission limits					
The emission limits are regulated in Chapter 2, paragraphs 4, 5 and Annex 2 of the German Immission Control Ordinance "Erste Verordnung zur Durchführung des Bundes-Immissionsschutzgesetzes (Verordnungüber kleine und mittlere Feuerungsanlagen - 1. BImSchV)". Boilers operated with solid fuels shall only be installed, possess the quality and be put into operation if they fulfil the following specifications of the 1. BImSchV.					EN 303-5:2012	Pellets – C1
	Fuel acc. to §3 (1)	Nominal output range kW	Dust g/m³	CO g/m³	Annex C, Deviation from Germany, C.5.1	
	Numbers 1 to 3a	≥ 4 ≤ 500	0.09	1.0		
	14dilibels 1 to od	> 500	0.09	0.5		
Stage 1:	Numbers 4 to 5	≥ 4 ≤ 500	0.10	1.0		
Appliances,	11441110010 1160	> 500	0.10	0.5		
which will be	Number 5a	≥ 4 ≤ 500	0.06	0.5		+
installed	rtambor oa	> 500	0.06	0.5		
after 22.3.2010		≥ 30 ≤ 100	0.10	0.8		
	Numbers 6 to 7	> 100 ≤ 500	0.10	0.5		
		> 500	0.10	0.3		

NOTE Differing from sentence 1 for firing systems (appliances) which will exclusively be fired by fuels according to §3 Article 1 Number 4 in the form of split logs, the limits according to Stage 2 apply for firing systems (appliances) if they are installed after 31.12.2016.

Measurement results: PelTec - lambda 12

	Average emission values								
Boiler	Me	asured values		Converted	Converted values O ₂ =13%				
output	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [g/m³]	Dust [g/m³]				
Nominal	10.65	88	26	0.085	0.020				
Minimum	12.93	158	15	0.195	0.015				

Measurement results: PelTec - lambda 48

	Average emission values								
Boiler	Me	asured values		Converted v	Converted values O₂=13%				
output	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [g/m³]	Dust [g/m³]				
Nominal	7.78	47	30	0.036	0.018				
Minimum	10.88	58	24	0.057	0.019				

Test evaluation:

The measured emission values for PelTec - lambda 12, PelTec - lambda 48 do not exceed prescribed val-

Tested by:

Ing. Michal Havlů

Date: 10/2012

Signed:

Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

Signed:



Accredited test

1004.1* Test title: Test of heat output, input and efficiency

1005.1* number:

Combustion efficiency test - emissions

EN 303-5:2012

Test method:

Annex C

C.6 Deviation from Switzerland

Sample tested:

PelTec - lambda 12, PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement			Requirement specification	Test evaluation		
Ordinance on Air Pollution C 814.318.142.1) of 1985-12-1 Boilers operated with woody market if they fulfil the follow – declarations of conformity (– Figures 1, 212, 23 Annex 4 – Figures 31, 32 Annex 5 OA	6 (as at 2010-07-15). biomass shall only be put on the ing specifications of the OAPC: (Figure 20 OAPC); OAPC; APC. ed with coal or wood fuels shall		EN 303-5:2012 Annex C C.6 Deviation from Switzer- land	Pellets – C1		
Boilers for wood pellets, automatic stoking	300 40			+		
^a Referred to oxygen basis: – for boilers for natural state wood 13 % volume; – for boilers for coal 7 % volume.						
The sulphur content of coal, coal briquettes and coke shall not exceed 3 %. Boilers operated with non-woody biomass shall comply with the following specifications of the OAPC: - Figures 741, 742, 743 Annex 2 OAPC; - Figures 81, 82 Annex 3 OAPC. According to Figure 743, Annex 2 OPAC, non-woody biomass, such as biogenic waste and products from agriculture, may only be burnt in boilers with a heat input of at least 70 kW. Such units need an						

approval and shall meet stronger emission limits according to Figure 742, Annex 2 OAPC.

Measurement results: PelTec - lambda 12

	Average emission values				
Boiler	Me	Measured values			values O₂=13%
output	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [mg/m³]	Dust [mg/m³]
Nominal	10.65	88	26	85	20
Minimum	12.93	158	15	195	15

Measurement results: PelTec - lambda 48

	Average emission values					
Boiler	Me	asured values	Converted v	alues O₂=13%		
output	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [mg/m³]	Dust [mg/m³]	
Nominal	7.78	47	30	36	18	
Minimum	10.88	58	24	57	19	

Test evaluation:

The measured emission values for PelTec - lambda 12, PelTec - lambda 48 do not exceed prescribed val-

Tested by:

Ing. Michal Havlů

10/2012 Date:

Signed:


Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

Signed:

v. 3.00



Accredited test number:

1004.1* Test title: Test of heat output, input and efficiency

1005.1*

Combustion efficiency test - emissions

EN 303-5:2012

Test method:

Annex C

C.8 Deviation from Italy

Sample tested:

PelTec - lambda 48

Measuring equipment used:

Chapter III - Measuring and test equipment

Test results:

Requirement	Requiremer	Requirement specification		aluation
Italian emission limits for heating plants fuelled with biomass solid fuels	at 11% O ₂			
Plant nominal heat output (MW)	>0.035 ÷ <0.15	>0.15 ÷ <1		
	(>35kW÷<150kW)	(>150kW÷<1000kW)		
Total particulate matter	200mg/Nm ³	100mg/Nm ³	+	0
Total organic carbon (COT)		-		
Carbon monoxide (CO)		350 mg/Nm ³		
Nitrogen dioxide (expressed as NO ₂)		500 mg/Nm ³		
Sulphur dioxide (expressed as SO ₂)		200mg/Nm ³		
Italian emission limits for heating				
plants fuelled with non-biomass				
solid fuels				
	at 6% O ₂			
Nominal heat output (MW)	>0.35 (350kW)			
Total particulate matter	50 n	ng/Nm3		

Measurement results: PelTec - lambda 48

		Average emission values				
Boiler	Mea	Measured values			values O₂=11%	
output	O ₂ [%]	CO [ppm]	Dust [mg/m³]	CO [mg/m³]	Dust [mg/m³]	
Nominal	7.78	47	30	44	23	
Minimum	10.88	58	24	72	23	

Test evaluation:

The measured emission values for PelTec - lambda 48 do not exceed prescribed values.

Tested by:

Ing. Michal Havlů

10/2012 Date:

Signed:

Reviewed by: Ing. Stanislav Buchta

Date:

10/2012

v. 3.00



Accredited test number:

Test method:

1005.1*

1006.1* Test title: Function test of control, regulation and safety elements

Combustion efficiency test - emissions

EN 303-5:2012

Art. 5.13, 5.14, 5.16.1, 5.16.2, 5.16.3

EN 303-5:2012 Art. 5.9, 5.10.4


Sample tested: PelTec - lambda 12, PelTec - lambda 48

Chapter III - Measuring and test equipment Measuring equipment used:

Test results:

Requirement	Specification of requirement	Evaluation	Note
Function check of the temperature controller and safety temperature limiter at the boiler			
The water-side flow rate shall comply with that specified for the nominal heat output test. The flow temperature of 75 °C shall not be exceeded at the start of the test °C.			
Adjust the firing so that it corresponds to the nominal heat output Q_{N} of the boiler. A steady state condition shall be reached and the outlet pressure at the flue gas section shall be according to the nominal heat output setting. For manual stoked boilers, the boiler shall be refuelled after reaching steady state with a full batch before starting the test.			
The dissipated output shall be reduced to (40 ± 5) % of the nominal heat output of the boiler, circulating pump running in continuous operation; temperature controller adjusted to maximum set value.	EN 303-5:2012 Art. 5.13	+	
When the temperature controller is operating normally, the measured flow temperature shall not exceed 100 °C; the safety temperature cut out or limiter or the device for dissipating excess heat shall not trigger.			
Repeat the test with the temperature controller out of function. This time, check if the safety temperature limiter/detector switches off the firing system at the highest value specified by the boiler manufacturers and if all hazardous operation states are avoided (see 4.1).			

Requirement	Requirement specification	Test evalua- tion	Note
Function test for the rapidly disconnectable firing system			
Sudden absence of heat dissipation			
The water-side flow rate shall comply with that specified for the nominal output test. The flow temperature of 75 °C shall not be exceeded at the start of the test.			
Adjust the firing so that it corresponds to the nominal heat output Q_N of the boiler, a steady state condition is reached and the outlet pressure at the flue spigot is according to the rated heat output.			
The heat consumption is set to 0; water circulation in the boiler is permitted; temperature controller is adjusted to manufacture recommended maximum set value.			
Check if the safety temperature limiter or the temperature controller switches off the firing system and all hazardous operation states are avoided.	EN 303-5:2012 Art. 5.14	+	
- Loss of the electrical power supply			
The water-side flow rate shall comply with that specified for the nominal heat output test. The flow temperature of 75 °C shall not be exceeded at the start of the test.			
Adjust the firing so that it corresponds to the nominal heat output Q_N of the boiler, a steady state condition is reached and the outlet pressure at the flue gas section is according to the rated heat output.			
The electrical power supply including the circulation is cut off, check that no hazardous operation conditions occur.			
For the evaluation of the temperatures and the CO-concentrations, only mean values at a maximum average time of one minute shall be considered.			
Safety test of consequences of fuel overload and effect of a blockage of the fuel supply The safety of the boiler shall be checked at continuous operation of the boiler with the fuel feed rate of the stoking device set at possible maximum capacity, taking into account failures according to the risk analyses and the electrical safety. If other fuel feed rates lower than the maximum are categorised as critical by the risk analysis, these shall also be tested. The functionality of the safety device for the shut-down of the fuel shall occur by prevention of the ignition after release of fuel if no or insufficient combustion in the combustion chamber occurs. The test for blocked fuel line shall be achieved by deactivating the stoking device. The requirements specified in 4.3.4 shall be satisfied.		+	



Requirement	Requirement specification	Test evalua- tion	Note
Loss of combustion air supply The safety of the heating boiler shall be checked at maximum heat input under the following conditions:			
 failure of combustion air fan; failure to close of the adjustable combustion air supply. 	EN 303-5:2012		
In each case, only one failure shall be simulated. The CO concentrations in the boiler shall not exceed 5 % volume.	Art. 5.16.3	+	
The measurement of CO concentration shall be carried out in the flue are measuring postion			
in the flue gas measuring section. Test of combustion air supply loss			

Note:

- Compliant
- Non-compliant
- 0 Not applicable
- x Not assessed

Measurement results:


Controlling thermostat				
Temperature	[°C]	Note:		
Pre-set	85 °C	Temperature set on the operating thermostat regulator		
Shutdown	84 °C	Fan and stoking switched off (suppression mode)		
Restoration of operation	82 °C	Fan and stoking operation restored		

Temperature limiter (manual restoration of temperature) STB				
Temperature	[°C]	Note:		
Pre-set	90 °C	Temperature set on the temperature limiter		
Shutdown	95 °C Fan switched off			
Restoration of operation	The boiler irreversibly switched off. In order to restore operation manual intervention required, after the temperature drops under the limiter switching temperature.			

<u>Test evaluation:</u> Proper functioning of safety elements has been verified

Tested by: Ing. Michal Havlů Date: 10/2012 Signed:

Reviewed by: Ing. Stanislav Buchta Date: 10/2012 Signed:



The test methods in this Report were applied without any deviations, additions or exceptions.

V. <u>List of source materials</u>

- Order B-44560 of 2012-09-10
- Contract B-45560/31 of 2012-09-17 and the Amendment to the Contract of 2013-03-27
- EN 303-5:2012 Heating boilers Part 5: Heating boilers for solid fuels, manually and automatically stoked, nominal heat output of up to 500 kW Terminology, requirements, testing and marking
- Instructions for assembly, installation and operation of the boiler
- A set of required drawing documentation as per EN 303-5:2012; Boiler PelTec lambda 12, PelTec lambda 18, PelTec lambda 24, PelTec lambda 36, PelTec lambda 48

The persons named below are accountable for the accuracy of the above-specified data:



Ing. Stanislav Buchta
Head of Boilers and Industrial Heat
Equipment Department

Ing. Jiří Dvořák
Head of Heat and Environment-Friendly
Equipment Test Station

Appendix 1: Deviations from Austria

According to the agreement under Article 15a B-VG "Energy Saving", the current requirements are in force for nominal heat output and for minimum heat output for the hot-water boilers burning biogenous fuels, with automatic fuel supply.

Efficiency:

EN 303-5:2012, Annex C, Deviations from Austria, C.2.2

up to 10 kW	80 %
>10 kW to 200 kW	(72.3 + 7.7 log Pn) %

The comparison of the measured values with the required values is shown on pp. 47 to 50 hereof.

According to the Article 15a B-VG Agreement "Preventive Measures for Small-Scale Heating Systems," the current requirements for hot-water boilers burning solid biogenous fuels, with automatic fuel supply, are as follows:

EN 303-5:2012, Annex C, Deviation from Austria, C.2.3

	Emission limits mg/MJ			
Parameter	Wooden pellets Central heating plants			
	Limits for nominal output Limits for minimum outputs			
СО	250	375		
NO _x	150			
OGC/THC	30			
Dust	40			

The comparison of the measured values with the required values is shown on pp. 47 to 50 hereof.

Conclusion

The Engineering Test Institute, Public Enterprise, the owner of the Certificate of Accreditation to perform accredited tests issued by the Czech Accreditation Institute, hereby gives the following summarization:

This is to confirm that the tests of emissions and of performance of the hot-water boiler, type designation PelTec - lambda 12, PelTec - lambda 18, PelTec - lambda 24, PelTec - lambda 36, PelTec - lambda 48,

manufactured and sold by the Company Centrometal d.o.o., Glavna 12, 40306 Macinec, Croatia,

have been concluded with positive results, which means that the product fulfils the requirements of the standard EN 303-5, and in particular of

EN 303-5:2012, Annex C, Deviation from Austria, C.2.2, C.2.3 15a B-VG "Energy Saving"

15a B-VG "Preventive Measures for Small-Scale Heating Systems"

Tested by: Ing. Michal Havlů Date: 10/2012 Signed:

Reviewed by: Ing. Stanislav Buchta Date: 10/2012 Signed: